

INHIBITED WATER METER CLEANER

Inhibited Acid Cleaner

Form: Liquid

Color: Clear, Green

Odor: Acidic

pH: 1.00

Solubility (in water): Soluble
(in mineral spirits): No data available

VOC Content (% by weight): <0.5

Flash Point (Closed Cup): >200°F

Specific Gravity: 1.1 g/ml

Density: 9.18 lbs/gal

Storage Stability (at 70°F): 1 year

<u>Ingredients</u>	<u>C.A.S. #</u>
Water.....	7732-18-5
Hydrochloric Acid	7647-01-0
Surfactant.....	Proprietary
PEG-2 Hydrogenated	
Tallow Amine.....	61791-26-2
Acid Blue 93	28983-56-4

Use as...	
•	Coil De-Limer
•	Rust and Mineral Stain Remover
•	Lime Scale, Scum and Slime Remover
•	Tile and Grout Cleaner
•	Ammonia Neutralizer
•	Dairy Tank Cleaner
•	Kennel Cleaner

DIRECTIONS: To clean and descale water meters and metal parts, submerge parts in undiluted INHIBITED WATER METER CLEANER and soak until all deposits are dissolved. Rinse thoroughly with clean water. For light deposits, dilute INHIBITED WATER METER CLEANER with 3 to 5 parts water. To descale boilers, cooling towers, condensers, heat exchangers, and other water handling systems, dilute INHIBITED WATER METER CLEANER with 8 to 10 parts water. Allow solution to soak or circulate in system for 4 to 8 hours, until scale is removed. Flush system thoroughly with clean water. Rinse empty container before disposal.

HMIS®			NFPA®		
	Severe	4	Extreme		
Health	Serious	3	High	Health.....	3
Flammability	Moderate	2	Moderate	Flammability.....	0
Reactivity.....	Slight	1	Slight	Reactivity.....	0
Personal Protection.....	Minimal	0	Insignificant	Special Precautions.....	None