

TANK PROTECTOR

Storage Tank Protector

Form: Liquid

Color: Cloudy White

Odor: None

pH: 11.00-12.00

Solubility (in water): Soluble
(in mineral spirits): Insoluble

VOC Content (% by wt.): 0

Flash Point (ASTM D-7821): None

Specific Gravity: 1.10 g/cm³

Density: 9.18 lbs/gal

Storage Stability (at 70°F): 1 year

Ingredients

C.A.S. #

Water.....7732-18-5
Sodium Silicate.....1344-09-8

Great for use around...
<ul style="list-style-type: none">• Farms• Golf Courses• Fire Departments• Municipalities

DIRECTIONS: In fire truck tanks, emergency storage tanks and holding tanks, add 1 gallon of TANK PROTECTOR for each 1,000 gallons of water. Treat with TANK PROTECTOR every time the tank is filled. In flowing water systems, inject or meter 3 gallons of TANK PROTECTOR per 10,000 gallons of water. After a 6 to 8 week initial treatment period, decrease the injected or metered rate to 1 gallon per 10,000.

HMIS®			NFPA		
	Severe	4	Extreme		
Health.....0	Serious	3	High	Health	0
Flammability	Moderate	2	Moderate	Flammability.....	0
Reactivity	Slight	1	Slight	Reactivity.....	0
Physical Hazard.....	Minimal	0	Insignificant	Special Precautions.....	None