BOILER PRO S PLUS

WATER TREATMENT

SOFT WATER BOILER TREATMENT

Superior protection in soft water systems Contains oxygen scavenger and steam line treatmen

DANGER

May be corrosive to metals. Causes severe skin burns and eye damage.

KEEP OUT OF REACH OF CHILDREN

NET CONTENTS: 1 5 20 35 55 Gallon(s)

P.O. Box 245013 Milwaukee, WI 53224 (800) 776-7192 www.sharecorp.com

CORP

ATER TREATMEN

いし

301132230



May be corrosive to metals. Causes severe skin burns and eye damage.

Keep only in original container. Do not breathe mist spray. Wash thoroughly after handling. Wear eye protection, protective clothing, protective gloves. Wash contaminated clotting before reuse.

IF SWALLOWED: ringe mouth. Do NOT induce vomiting IF ON SKIN (OR HAIR): Take off immediately all conteminated clothing. Hinse skin with water/shower. IF INIALED: Remove porton to foresh air and keep confertable for infesting. IF IN EXES: Ringe cautiously with water for several minites. Remove context lepses: if present and easy to dd. Gontinue ringing Immediately call a doctor, a POISON CENTER.

Absorb spillage to prevent material damage.

STORAGE: Store locked up. Store in corrosive resistant container with a resistant inner liner.

DISPOSAL: Dispose of contents/container to comply with local/regional/national/international regulations.

NFPA* RATINGS:

DANGED

Health: 2; Flammability: 0; Reactivity: 0

CONTAINS/CAS#:

Water (7732-18-5); Proprietary (Mixture); N,N-Diethylmonoethanolamine (100-37-8); Sodium Metabisulfite (7681-57-4); Sodium Sulfite (7757-83-7); Potassium Hydroxide (1310-58-3);Tetrapotassium Pyrophosphate (7320-34-5)

WARNING: This product contains, or may contain, trace quantities of a substance(s) known to the state of California to cause cancer and/or reproductive toxicity.

TRIDENT BOILERPRO S PLUS is a multi-functional formula with all the necessary chemicals for a complete boiler treatment in one convenient liquid. It combines hardness control with oxygen scavengers and a volatile amine corrosion inhibitor that travels with the steam to protect steam and condensate plumbing.

DIRECTIONS:

The dosage of **TRIDENT BOILERPRO S PLUS** will depend on the percent of condensate returned, makeup water characteristics and initial cleanliness of heat transfer surfaces. The treatment program must be accompanied by a program of regular blowdown to remove sludge and suspended solids from the boiler. **TRIDENT BOILERPRO S PLUS** may be fed on a "one shot" basis or with an automated continuous system. Gradual and continuous feeding is recommended for industrial process and other large boilers. **TRIDENT BOILERPRO S PLUS** may be mixed with other boiler treatment chemicals and diluted with water for convenient feeding. If the boiler water system has not been previously treated, add a starting dosage of twice the amount recommended for weekly dosages for the first four weeks.

For weekly maintenance: Add 1/2 gallon (2 quarts) of TRIDENT BOILERPRO S PLUS per week for each 25 horsepower of boiler capacity, or 1 gallon for every 125 gallons of boiler water capacity. This use rate may vary due to feedwater hardness and differences in a boilers rated horsepower versus the boilers operational horsepower.

Blowdown: Open the blowdown valve until the level drop in the sight glass is reached, recommended starting point is 2 inches twice a week. Blowdown schedules will vary depending upon water hardness and permissible cycles of concentration.

For industrial and commercial use only.

For additional information, see Safety Data Sheet.



1960.052015